



1-Placement of equipment is dependant on the size of the communication room. Modifications will be provided at the time confirmation of room size is received to UIT -IPA
 2- Sprinkler heads, water pipes or drains should NOT be placed over network cabinets
 3-All rooms will have a lock with a number 3 key.

REVISION:	
1	
2	
3	
4	
5	

PROJECT NAME:
UIT – Infrastructure Planning Standards

DRAWING NAME:
Comm Room Shell-Build Out

DRAWN BY: **TW**
 APPROVED BY: **MD**
 DATE: **Nov. 15, 2016**
 SCALE: **NTS**

PROJECT #:
 ISSUE #: **1**
 DRAWING #:
UIT-IPA-03